

# Preliminary Assessment Report

## Project 3016772, 410 12TH AVE E

---

**Assessment Completed:** 1/15/2014

**Project Description:** SDR - Construct two three-story townhouse structures, one duplex and one triplex. No parking to be provided, existing structure to be demolished.

**Primary Applicant:** [Bradley Khouri](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

### Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

### Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### DPD Drainage Requirements

Arthur Thomas Richardson, (206) 684-3655, [art.richardson@seattle.gov](mailto:art.richardson@seattle.gov)

#### DPD Land Use Requirements

Scott Alan Ringgold, (206) 233-5132, [scott.ringgold@seattle.gov](mailto:scott.ringgold@seattle.gov)

#### DPD Preapplication Site Visit Requirements

Kathleen H Wilson, (206) 233-7932, [Kathleen.Wilson@seattle.gov](mailto:Kathleen.Wilson@seattle.gov)

#### Seattle City Light Requirements

Ray Ramos, (206) 615-1193, [ray.ramos@seattle.gov](mailto:ray.ramos@seattle.gov)

#### Seattle Department of Transportation Requirements

Joel Prather, (206) 615-0772, [joel.prather@seattle.gov](mailto:joel.prather@seattle.gov)

#### Seattle Public Utilities Requirements

Jennyfer Jacobsen, (206) 684-8766, [JacobsJS@seattle.gov](mailto:JacobsJS@seattle.gov)

#### Water Availability

P Kimani, (206) 684-5975, [Karen.Younge@Seattle.Gov](mailto:Karen.Younge@Seattle.Gov)

## Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

## Requirements

### **DPD Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

#### **Existing Public Drainage Infrastructure**

Sanitary sewer main location: E Harrison St

Sanitary sewer main size: 8-inch

Storm drainage main location: E Harrison St

Storm drainage main size: 12-inch

#### **Drainage**

The drainage point of discharge (SMC 22.805.020) is located at: Weep hole.

#### **Flow Control Compliance**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed [Construction Stormwater Control and Soil Amendment Standard Plan](#) is required.

Submit a [Standard Drainage Control Plan for Small Projects](#) including the [Green Stormwater Requirement Calculator](#).

For projects with 5,000 square feet or more of new plus replaced impervious surface, a comprehensive drainage control plan and construction stormwater control plan shall be prepared by a licensed engineer.

#### **Water Quality**

No requirements

#### **Wastewater**

**An extension of the public sanitary sewer is required (SMC 21.16.260).** Side Sewer code allows only 8 units per 6" lateral. Ex lateral appears to have 8 units or more.

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

#### **Permanent and Temporary Dewatering**

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following:  
Other. Former combined

#### **Side Sewer**

The existing side sewer for a new or converted building or dwelling unit may be reused pursuant to SMC 21.16.240.

In order to reuse an existing side sewer, the [Side Sewer Evaluation and Certification Form](#) must be completed by a licensed engineer.

### **DPD Land Use Code Requirements**

#### **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required,

please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

### **12TH AVE E**

New structures must be designed to accommodate right-of-way improvements. To ensure that driveways and pedestrian access points are designed to match these future street improvements, please use the Building Grade Calculator, which can be found at <http://www.seattle.gov/transportation/gradesheetintro.htm>

Because full street improvements are not being required for this project, or the project qualifies for a reduced street improvement, a no-protest agreement is required. This form can be found [here](#).

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.

<http://www.seattle.gov/transportation/treeplanting.htm>.

Existing curbcuts that will no longer be used are required to be removed, and the curbline reinstalled, per SDOT standards.

Any planting proposed within the ROW must be reviewed and approved by DPD and SDOT.

A 3.5' foot setback is required. Please label on Site Plan.

A 3' foot setback is required in addition to setback listed above. Please label on site plan.

### **Land Use**

It appears your project will require Streamlined Design Review. A pre-submittal conference will be required. Please see Land Use Code Section 23.41.018.

### **Notes to Applicant**

Note proposed stairways located in required 23.53 setback.

### **Other Requirements**

A presubmittal conference is required before to submitting an application. Details for preparing and submitting a presubmittal request form can be found at our Web site ([http://www.seattle.gov/dpd/Publications/Forms/Building Permits/default.asp](http://www.seattle.gov/dpd/Publications/Forms/Building_Permits/default.asp)).

## **Pre-Application Site Visit (PASV) Requirements**

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

### **ECA Mapping Unit and Type**

Non-ECA

### **Existing ROW Conditions**

#### **12TH AVE E**

Street conditions:

Asphalt paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 4 inch inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

### **Tree Protection**

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

## **Inspectors Notes**

This report does not address any construction activities.

## **Seattle City Light Requirements**

### **Street/Alley Requirements**

#### **12TH AVE E**

Working Clearance: State law requires construction workers, their tools, machinery, equipment, and materials to maintain a 10-foot clearance from power lines. Review WAC 296-24-960 and OSHA 1910.333(c)(3)(i). Transmission lines require greater clearance. To work near power lines, notify SCL well in advance to de-energize and ground the lines, or relocate the lines temporarily. This SCL work is done at the project's expense. There is an overhead high voltage line along 12th Ave E.

### **Easements**

SCL power easement is required. Property survey may be required at project's expense.

SCL blanket power easement over the entire parent parcel may be required. Property survey may be required at project's expense. If this is a unit lot subdivision, a blanket easement is needed.

Other requirements: The existing parent parcel is considered one site. The electrical service to the new buildings will need to be consolidated from one service strike from SCL's distribution system. Per SCL Requirements for Electric Service Connection, <http://www.seattle.gov/light/contractors/resc/>, Chapter 5, page 28: "Single Service Rule", Seattle City Light will provide only one service to a site or building. Additional services will be supplied only at SCL's option and will be agreed to in writing. Please contact your Electrical Service Representative well in advance of construction for clarification and electrical service advice.

### **Conservation**

Built Smart Programs - SCL offers developers of 5+ unit multifamily buildings incentives for installation of energy efficiency measures. From insulation and windows to lighting and appliances, take advantage of new technologies and construct a more efficient building with our help. For more information: contact Beth Rocha at (206)684-5945 / [beth.rocha@seattle.gov](mailto:beth.rocha@seattle.gov) or Meghan Pinch at (206)684-3901 / [meghan.pinch@seattle.gov](mailto:meghan.pinch@seattle.gov)

### **Notes to Applicant**

For new service, an Application for Electrical Service must be submitted to Seattle City Light. Please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Candace Gruber, 206-684-0791, [candace.gruber@seattle.gov](mailto:candace.gruber@seattle.gov). Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SDOT Requirements**

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: [http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm). Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

### **SDOT Permitting Information**

Initial Review Deposit: \$2,500

SDOT Plan Requirements: Engineered plan

SDOT Permit Requirements: Group 3: Street Use Major (Type 45). A 60% complete street improvement plan (SIP) must be approved by SDOT prior to your DPD construction intake appointment. SIP Design Guidance is required for 60% complete SIP approval; apply early. Please visit SDOT's Street Use website at: [http://www.seattle.gov/transportation/stuse\\_sip.htm](http://www.seattle.gov/transportation/stuse_sip.htm) to obtain SDOT Client Assistance Memos (CAMs) and application materials to assist in developing your street improvement plan (SIP).

All private encroachments in the public right-of-way (ROW) require a 30-day permit that is renewed annually. A drainage review is required as part of the Street Use Permit if more than 750 square feet of land disturbing activity will take place in the right of way.

## **Street Improvement Requirements**

### **12TH AVE E**

Tree planting. See Seattle Right of Way Improvements Manual (ROWIM) and City of Seattle Standard Plans 030, 100 and 424. Contact SDOT Urban Forestry for residential projects at (206) 684-TREE; for all others at (206) 684-5693 for approval of species and placement. Ex sidewalk width is inadequate for st trees.

All improvements on private property must accommodate the right of way elevation at the property line using the standard cross-section in the ROWIM. Right of way grading may be required to provide vehicular and pedestrian access that meets the standard cross-section.

Grade 3.5' arterial ROW setback @ st grade w/ access.

New/replacement sidewalk: See Seattle Right of Way Improvements Manual (ROWIM) as well as the City of Seattle Standard Plan 420, 421 and 422.

New/Replacement Curb: See Seattle Right of Way Improvements Manual (ROWIM) and the City of Seattle Standard Plan 410.

## **Discretionary ROW Improvements**

Utilities such as poles, utility vaults, and fire hydrants may need to be relocated to accommodate your required street improvements. See Right of Way Improvement Manual (ROWIM) section 4.20 for clearance requirements.

Other requirements: PSS main line extension per DPD..

## **SPU Requirements**

### **Flow Control Compliance**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. For projects with 5,000 square feet or more of new and replaced impervious surface, a comprehensive drainage control plan shall be prepared by a licensed engineer.

### **Water Availability**

Your water availability assessment has been approved.

### **Solid Waste**

Your project is fronted by a major arterial. An alternate location for pickup of your solid waste is required. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

[http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos\\_004542.pdf](http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf). For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

## **Other Requirements**

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes

before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, [Michale.Crooks@seattle.gov](mailto:Michale.Crooks@seattle.gov), or visit the [Licensing and Tax Administration Division website](#).